

26.01.2026 / North Sea Summit

International Optimization of Full Load Hours in the German Bight – Cross-Border Radials


Dr. Bernhard Stoevesandt, Dr. David Baumgärtner,
Dr. Torge Lorenz, Jonas Kaczinski

Executive Summary

International Optimization of Full Load Hours in the German Bight

Effects of the spatial reallocation to Danish and Swedish areas


- **Increase system-level efficiency of offshore wind in the German Bight** by reallocation of offshore wind farm capacity to Danish and Swedish areas
- **Reduced wake losses** through lower power density and improved spacing between offshore wind farms
- **Higher full load hours and energy yield** in German, Danish and Swedish areas
- **Moderate increases in installation and O&M costs** due to longer distances are **overcompensated by higher energy production**
- Additional areas achieve even higher full load hours and lower cost indices, **leading to a net improvement in system-level energy yield and cost efficiency** [€/MWh]



International Optimization of Full Load Hours in the German Bight

Objective


- **Increase system-level efficiency of offshore wind in the German Bight** through spatial optimization of offshore wind deployment
- Total installed capacity and grid connection to the German electricity grid remain unchanged
- The base scenario follows the continuation of the Site Development Plan (FEP 2025)
- Two additional scenarios evaluate **cross-border spatial reallocation** to Denmark and Sweden, while keeping total capacity in line with the BSH base case scenario




International Optimization of Full Load Hours in the German Bight

Scenario definition: increasing scale of cross-border spatial reallocation


Base Scenario



Scenario 1





Scenario 2



International Optimization of Full Load Hours in the German Bight

More energy at lower system cost through spatial optimization



- **Scenario 1 and Scenario 2 increase total energy yield**
- Higher energy yield outweighs higher installation and O&M costs, resulting in a lower cost index [€/MWh] in both scenarios

- Total installed capacity remains unchanged across all scenarios
- Including zones 3, 4, and 5, area N-5 and the capacities moved to the Danish and Swedish areas, as indicated on the previous page

Approach / Methodology

International Optimization of Full Load Hours in the German Bight

Scenario definition: power density as key control variable

In alignment with the FEP 2025 BSH scenario

Two scenarios evaluate **cross-border spatial allocation** to Denmark and Sweden, **maintaining the total installed capacity**

Base Scenario

- Capacities according to the FEP 2025 draft
- Average power density of **10.2 MW/km²** for all newly built offshore wind farms

Scenario 1 – Moderate Density Reduction

- Average power density reduced to **8.4 MW/km²** for newly built offshore wind farms
- Partial reduction of capacity at Doordewind I & II (4 GW → 2 GW)


Scenario 2 – Strong Density Reduction

- Average power density reduced to **6.6 MW/km²** for newly built offshore wind farms
- Further spatial reallocation of capacity


		Base Scenario		Scenario 1		Scenario 2	
Area	Zone	Capacity [GW]	Power Density [MW/km ²]	Capacity [GW]	Power Density [MW/km ²]	Capacity [GW]	Power Density [MW/km ²]
N-5	2	4.0	10.1	4.0	10.1	2.0	5.1
N-9	3	7.7	10.3	7.7	10.3	7.7	10.3
N-10	3	2.5	13.7	2.5	13.7	2.5	13.7
N-11	3	3.5	9.3	3.5	9.3	3.5	9.3
N-12.1-3	3	5.0	10.1	5.0	10.1	5.0	10.1
N-12.4-6	3	4.0	9.3	2.0	4.6	2.0	4.6
N-13	3	5.5	9.9	3.5	6.3	3.5	6.3
N-14	4	6.0	10.4	4.0	6.9	2.0	3.5
N-16	4	10.0	9.1	6.0	5.5	4.0	3.6
N-17 + N-20	4	4.0	8.6	4.0	8.6	2.0	4.3
N-19	5	4.0	7.1	4.0	7.1	2.0	3.6
Total		56.2	10.2	46.2	8.4	36.2	6.6
Other German OWFs		18.9		18.9		18.9	
Total DE		75.1		65.1		55.1	
DK North Sea		0.0		8.0	5.2	18.0	5.2
DK + SE Baltic Sea		0.0		2.0	8.5	2.0	8.5
Total		75.1		75.1		75.1	
Doordewind I and II		4.0	7.3	2.0	3.6	2.0	3.6

International Optimization of Full Load Hours in the German Bight

Spatial reallocation of offshore wind capacity (Scenarios 1 & 2)



Scenario 2 with 18 GW capacity (indicated in red) reallocated to the Danish North Sea



2 GW capacity (indicated in red) reallocated to the Danish and Swedish Baltic Sea in Scenario 1 and Scenario 2

International Optimization of Full Load Hours in the German Bight

General assumptions

Time Horizon & System Scope

- Fully developed state in 2045
- Relevant offshore wind projects in neighbouring EEZs (DE, DK, NL) considered
- Weather year 2012

Technology & Costs

- 22 MW offshore wind turbines
- Cost assumptions based on established Fraunhofer IWES studies

Operations & Availability

- Identical O&M service concept across all areas (SOV + helicopter, seasonal reinforcement)

Scenario Consistency

- Same assumptions applied to all scenarios
- Results reflect relative differences, not absolute optimization

International Optimization of Full Load Hours in the German Bight

CAPEX assumptions

CAPEX and installation for **offshore wind turbine generators** is calculated as the sum of three cost components:

- **Logistics costs** derived from OffshoreTIMES simulations
- **Soft costs** of **0.9 million € per MW**, corresponding to approximately **20 million €** for the **22 MW** turbines used in the new-build scenarios
- **Material costs** of **2.3 million € per MW**, corresponding to approximately **50 million €** for the **22 MW** reference turbine (including monopiles, transition pieces, inter-array cables, and scour protection)

CAPEX and installation for **offshore grid connection systems**:

- Based on **NEP 2023**, with adjustments by the TSOs
- Costs for offshore export cables (**6 million € per km**) and converter platforms (onshore and offshore combined) amounting to **1 billion € per GW**

Assumptions for failure rates, offshore processes, and logistics costs are based on: “Evaluation of various lifetime extension and repowering scenarios of offshore wind farms and offshore grid connection systems in the German Bight”



International Optimization of Full Load Hours in the German Bight

Relative cost-efficiency metric for scenario comparison

- Evaluation of scenarios at area level based on:
 - Energy yield (full load hours)
 - Cost index [€/MWh] not the same as a complete LCoE; for simplification, the cost index is defined as:

$$\text{Cost index} = \frac{(\text{construction cost}^1 + \text{O\&M cost}_{\text{OWF}}^2 + \text{O\&M cost}_{\text{offshore grid connection systems}})}{\text{energy yield}^3}$$

- For all relevant areas in the three scenarios, energy yield and operating costs are evaluated over a 35-year lifetime
- The cost index is normalized to the average cost index of the base scenario
- Relevant areas: Zone 3, 4 and 5, area N-5 as well as the new areas in the Danish North and Baltic Sea

1 sum of installation cost and CAPEX as defined on the previous slide

2 computed with Fraunhofer IWES *OffshoreTIMES*

3 computed with the Weather Research & Forecasting (WRF) model




Results


International Optimization of Full Load Hours in the German Bight

Base scenario: Full load hours (excl. availability) & cost index per area

Full load hours




Cost index




International Optimization of Full Load Hours in the German Bight

Scenario 1: Full load hours (excl. availability) & cost index per area

Full load hours




Cost index




International Optimization of Full Load Hours in the German Bight

Scenario 2: Full load hours (excl. availability) & cost index per area

Full load hours




Cost index



International Optimization of Full Load Hours in the German Bight

Energy yield increases due to reduced wake losses and lower power density

Scenario 2



- Reducing power density and wake interactions leads to higher full load hours
- Significant differences between areas reflect local wake exposure
- Zones 4, 5 and N-5 are less affected by wakes and show higher yields
- Danish and Swedish areas also achieve high full load hours
- Aggregated effect: total energy yield increases by 6% (S1) and 13% (S2)


Total capacity of the relevant areas listed above is 56 GW.

Scenario	Energy Yield	Change vs. Base [%]
Base	196 TWh	0.0
Scenario 1	208 TWh	6.2
Scenario 2	222 TWh	13.3

International Optimization of Full Load Hours in the German Bight

Installation costs: moderate differences driven by cable length

Scenario 2




- Differences in distance to shore directly drive export cable costs
- The Baltic Sea area shows the lowest installation cost due to short cable length
- Scenario 1 shows a slightly lower total installation cost than the base scenario
- Scenario 2 shows a higher total installation cost due to longer export cables to Danish areas

Scenario	Total Installation Cost	Change vs. Base [%]
Base	299.18 billion €	0.0
Scenario 1	298.78 billion €	- 0.13
Scenario 2	302.55 billion €	1.13

International Optimization of Full Load Hours in the German Bight

O&M costs: modest increase with distance to shore

Scenario 2



- O&M costs increase with distance to shore for OWFs in the Danish North Sea
- The new Baltic Sea wind farms show the lowest O&M cost due to a CTV-based service concept
- In Scenario 1, total O&M costs remain almost unchanged compared to the base scenario
- In Scenario 2, total O&M costs increase by 2.5%

Scenario	O&M per (MW·year)	Change vs. Base [%]
Base	41,693 €	0.0
Scenario 1	41,791 €	0.24
Scenario 2	42,717 €	2.46

International Optimization of Full Load Hours in the German Bight

Summary of the results

	Base Scenario				Scenario 1				Scenario 2			
	Capacity [GW]	Energy Yield [TWh]	FLH [h]	Cost Index	Capacity [GW]	Energy Yield [TWh]	FLH [h]	Cost Index	Capacity [GW]	Energy Yield [TWh]	FLH [h]	Cost Index
N-5	4	16.0	4,000	0.840	4	16.2	4,050	0.828	2	9.3	4,640	0.728
Zone 3	28	89.2	3,190	1.106	24	79.8	3,330	1.063	24	80.6	3,360	1.053
Zone 4	20	73.8	3,690	0.938	14	54.9	3,920	0.885	8	34.7	4,330	0.802
Zone 5	4	17.0	4,260	0.861	4	17.0	4,250	0.863	2	9.5	4,750	0.777
Total DE	56	196.1	3,500	1.000	46	167.9	3,650	0.962	36	134.1	3,730	0.946
DK-S-Baltic	-	-	-	-	2	8.9	4,430	0.699	2	8.9	4,430	0.699
DK-N	-	-	-	-	8	31.4	3,930	0.900	18	79.3	4,390	0.828
Total	56	196.1	3,500	1.000	56	208.2	3,720	0.941	56	222.3	3,970	0.894

- Reallocating capacity to Denmark and Sweden increases full load hours in German wind farms and reduces their cost index
- Additional Danish and Swedish areas achieve even higher full load hours and lower cost indices, leading to a net improvement in system-level energy yield and cost efficiency [€/MWh]

Contact

Dr. Bernhard Stoevesandt
Digital Asset Evaluation
Fraunhofer Institute for Wind Energy Systems IWES
Am Seedeich 45
27572 Bremerhaven, Germany

Phone +49 441 7985011
bernhard.stoevesandt@iwes.fraunhofer.de

